

Eagles Mere Borough Authority
Sanitary Sewer Installation, Correction or Replacement Permit

No. _____

Permit for Tapping and Connection Fee \$3000.00

Date _____

Name & Address of Property Owner _____

Location of Property _____

Rules & Regulations

1. No work shall be done by any property owner, his agent, or employee on any sanitary sewer lateral unless property owner has been advised the Sanitary Sewer Installation, Correction or Replacement Permit application has been approved by the Authority, paid the appropriate fees and obtained all State and Municipal Right of Way permits.
2. The Authority or its Inspector shall determine location of the connection and supply said connection to the sewer main. The property owner, his agent, or employee shall not break or otherwise damage the sewer main or allow surface water, mud or debris to enter the sanitary sewer. Arrangements for locating and/or adding a connection to the sewer main must be made prior to any lateral work being done with the Authority or their Inspector.
3. All connection service lines between the sewer main and the inside wall of the building shall be of 4" minimum pipe size with the exception of a pressurized system. All pipe shall be of a type allowed by the current edition of the BOCA Basic Plumbing Code with the exception that vitrified clay pipe will not be allowed. PVC must be a minimum of schedule 40. All service lines must be laid with a minimum grade of 1/8" to 1' with the best possible alignment and shall prevent the admission of ground water. **All vertical risers, traps, vents and cleanouts must be constructed using Schedule 40 fittings and glued in place to prevent separation or lifting by frost. Insulation board is to be placed over and around lateral pipes at vents and cleanouts to prevent frost penetration.** The design of the lateral shall be constructed according to the attached drawings.
4. The house lateral from the main to the inside house wall shall be inspected and comply with requirements of the current edition of BOCA Basic Plumbing Code. All tests will be made by the contractor and said **tests must also be observed by the Authority inspector.**
5. **Trenches shall not be backfilled until work has been inspected, tested and approved by the Authority Inspector.** In all cases the property owner shall be responsible for the cost of replacing road material and pavement to the same

thickness and quality as previously existed and shall meet construction requirements of the Pennsylvania State Highway.

6. The person, firm, or corporation procuring the permit shall properly maintain that portion of the backfilling trench located within the street right-of-way until such time as advised by the Authority that they are relieved of responsibility. Every person, firm or corporation whether owner or contractor excavating or altering street, lane, or alley of the Municipality shall provide good quality and sufficient barriers and maintain lighted lanterns or flares at night.
7. No storm or roof water, cellar seepage, sump pumps or ground water shall be drained to the house lateral or oils, tar, grease, gasoline, combustible gases or liquid, garbage, insoluble solids, or any substance which would impair or interfere with the sewer system or any part thereof in any manner, or with the function of the processes of the sewage treatment, shall be discharged into the sewer system.

I hereby agree that in the event the undersigned property owner or owners do not fulfill each of the above conditions that then I hereby authorize the Authority to disconnect such sewer connections and retain the permit fee for the use of said disconnection.

This agreement is made to induce the Authority to permit this installation, repair or replacement work to be done.

Eagles Mere Borough Authority

Secretary

Date Approved

Owner(s) or Representative of Owner

Project Inspected:

By _____

Date